

# CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

BOD-19-10-09-02


- Products:** SPC floor coverings – Vinyl floorings  
Structure: Marble grain with light embossed raindrop pattern  
Thicknesses: 3.2 – 8.0 mm
- Client:** econfloor austria e.U  
Bahnhofstr. 110  
5204 Strasswalchen  
Austria
- Order:** Testing and classification of selected properties according to EN 14041:2008 (CE-labelling)
- Test report:** 2718053
- Test results:**

Properties	Results	Declaration according to EN 14041:2008
Reaction to fire according to EN ISO 9239-1:2010 and EN ISO 11925-2:2011; Classification according to EN 13501-1:2010 - Critical heat flow - Smoke production	11.3 kW / m <sup>2</sup> 519 % * min	B <sub>fl</sub> -s1
Anti-sliding properties according to EN 13893:2003	μ = 0.32	class DS
Formaldehyde emission according to EN 717-1:2004	undetectable	class E1

Dresden, 09/10/2019



Head of laboratory

Engineer in charge